



Dear customer,

With regards to the requirements laid out in DIN 51130:2014 for determination of anti-slip property, the article under the reference

DECAL FINISH 100.80 FLOORGRAPHIC

DECAL FINISH 200.80 FLOORGRAPHIC

are classified as R9.

TEST CARRIED OUT

- DIN 51130:2014 Testing of floor coverings – Determination of anti-slip property – Workrooms and fields of activities with slip danger – Walking method – Ramp test.

Best regards.

R&D Department, Decal- Think Green!.